

8<sup>th</sup> September 2025

### Statement – Fire Classification according to EN 13501-1

#### Product:

**Ri-Jet M96 Series**

This statement defines the fire classification, as per clause 8.2 of EN 13501-1:2018, assigned to the abovementioned product, on the basis of testing conducted on this reference or on a product deemed equivalent for this purpose, at accredited external laboratories, according to the following European standards:

- EN 13501-1:2018 - Fire classification of construction products and building elements - Part 1: Classification using test data from reaction to fire tests.
- EN ISO 11925-2:2020 - Reaction to fire tests for building products - part. 2 -ignitability when subjected to direct impingement of flame.
- EN 13823:2020+A1:2022 - Reaction to fire tests for building products excluding floorings exposed to the thermal attack by a single burning item.

The product, in relation to its fire reaction behavior, is classified:

**B**

The additional classification in relation to smoke production is:

**s1**

The additional classification in relation to flaming droplets/particles is:

**d0**

This classification is valid for the following end use conditions: glued on non-combustible or gypsum plasterboard support/backing.

The format of the reaction to fire classification for construction products except flooring is:

| Fire behaviour |          | Smoke production |          |          | Flaming droplets |          |
|----------------|----------|------------------|----------|----------|------------------|----------|
| <b>B</b>       | <b>-</b> | <b>s</b>         | <b>1</b> | <b>-</b> | <b>d</b>         | <b>0</b> |

Please be aware that this document does not represent a type approval or certification of the product under the Construction Products Regulation.

DISCLAIMER: This information is for guidance only and represents our most up-to-date knowledge. It does not constitute any warranty, expressed or implied, and we cannot assume any liability for damage caused through its use. This statement is only intended for the recipient and cannot therefore be transferred to any third party. This publication replaces all previously published versions, and any and all information is subject to change without notice. We cannot assume any liability for using our products in conjunction with other materials. All our products are sold subject to Fedrigoni Self-Adhesives general sales conditions. their materials. All our products are sold subject to Fedrigoni Self-Adhesives general sales conditions.

**FEDRIGONI**  
**Self-Adhesives**  
Ritrama S.p.A.  
Registered and head office  
Offices and slitting  
and distribution centers  
Via Senatore Simonetta 24  
20867 Caponago, Italy  
T +39 02 955 459 1  
F +39 02 955 459 01

Share capital  
€ 9.000.000 i.v.  
VAT number IT 01676140153  
Sole shareholder Fedrigoni S.p.A.  
Business register MB  
Monza e Brianza  
Comp. Reg R.E.A. N. 1871535  
  
info.caponago@fedrigoni.com  
fedrigoni.com

Production sites  
Viale Industrie 30  
20060 Basiano (MB), Italy  
T +39 02 923 948 1  
F +39 02 923 948 39  
  
Polo Ind.le Berbentina  
60041 Sassoferrato (AN), Italy  
T +39 073 297 061  
F +39 073 296 436

Directing and  
controlling by  
**Fiber JVCo S.p.A.**

